

## A Petri Net Based Deadlock Prevention Approach for Flexible Manufacturing Systems<sup>1)</sup>

LI Zhi-Wu WANG An-Rong

(School of Electro-Mechanical Engineering, Xidian University, Xi'an 710071)

(E-mail: zhwli@xidian.edu.cn; an-rong-wang@sina.com)

**Abstract** A deadlock prevention strategy for flexible manufacturing systems is developed based on Petri nets and their structural analysis. The concept of elementary siphons is proposed, it is a class of SMS (strict minimal siphons) with a smaller cardinality, particularly in the Petri net models of large-scale systems. By adding a control place for each elementary siphon to make it never be emptied, deadlocks can be prevented for a special class of Petri nets, namely  $S^3PR$ . That means not all SMS need to be considered when ensuring no siphon loses its tokens. For  $S^3PR$ , An approach is proposed for finding elementary siphons and SMS. Compared with the existing methods that control all SMS in a Petri net, the deadlock prevention policy has at least three advantages: 1) only a smaller number of SMS need to be controlled, hence the deadlock-freeness or live Petri net model obtained has less additional places and arcs; 2) not need to compute the set of siphons beforehand; and 3) this policy is more suitable for large-scale Petri nets. These methods are illustrated with an example.

**Key words** Petri nets, deadlock prevention, elementary siphon, FMS

### 1 Introduction

Based on Petri nets, several methods have been developed to deal with deadlock problems in FMS context. The first one is to limit the number of processing parts entering an FMS. This method ensures the liveness of Petri net model although it is much conservative and hence deteriorates the system productivity and resource's utilization<sup>[1,2]</sup>. The second one is to avoid deadlocks by controlling requests for resources. The aim of this method is to forbid the request for a resource if permission of this request will lead to deadlocks<sup>[3]</sup>. In Petri net formalism, this method intentionally disables an enabled transition in order to avoid deadlock states to be reached. It is conservative as well. The third one is to ensure deadlock-free by modifying the structures of Petri net models<sup>[4,5]</sup>, which is usually called deadlock prevention. A control place is added for each SMS such that every SMS becomes a controlled one and hence it cannot be cleared of tokens. The drawback of the method proposed in [4] is that the resultant Petri net model becomes more complex due to the numerous additional places and arcs. The last one is called deadlock detection and recovery<sup>[6,7]</sup>. Once deadlocks are detected in Petri net models, automatic or manually actions will be employed. High productivity and resource's utilization can generally be achieved by this method, which however requires some auxiliary devices. Moreover, some unlocking control software must be programmed when designing controllers for robots, machine tools, etc<sup>[8,9]</sup>.

This paper proposes a deadlock prevention method based on elementary siphons.  $S^3PR$ <sup>[4]</sup> is used for modeling FMS in this paper. We verify that if elementary siphons are properly controlled, all SMS in a Petri net can possibly be marked and the controlled  $S^3PR$  is hence live. Because the number of elementary siphons is smaller than that of SMS, the controlled Petri net has a smaller number of additional control places and arcs. We assume

1) Supported by the Young Workstation Funds of Xidian University of P. R. China(YWF200201001)

Received May 27, 2002; in revised form December 5, 2002

收稿日期 2002-05-27; 收修改稿日期 2002-12-05



the reader to be familiar with Petri nets<sup>[10]</sup>.

## 2 Elementary siphons of Petri nets

In this section, we present the concept of elementary siphons. Elementary siphons are a unique type of SMS. The number of them is much smaller than that of SMS, particularly in a large Petri net structure. This concept is suitable not only for  $S^3PR$  class but also for more general Petri nets. This research reveals that a live controlled  $S^3PR$  can be obtained by just controlling its elementary siphons rather than all SMS in it.  $\Pi_{ES}$  is used to denote the set of elementary siphons in an  $S^3PR$  net system in the sequel.

**Definition 1.** Let  $N=(P, T, F)$  be a Petri net (not necessarily an  $S^3PR$ ) and  $S \subseteq P$  be a siphon of  $N$ . A P-vector  $\lambda_S$  is called the characteristic P-vector of  $S$  iff  $\forall p \in S, \lambda_S(p) = 1$ ; otherwise,  $\lambda_S(p) = 0$ .

**Definition 2.** Let  $N=(P, T, F)$  be a Petri net,  $S \subseteq P$  be a siphon of  $N$ , and  $\lambda_S$  be the characteristic P-vector of  $S$ .  $\eta_S$  is called the characteristic T-vector of  $S$  if  $\eta_S^T = \lambda_S^T \cdot C$ .

**Theorem 1.** The characteristic T-vector of the support of a P-invariant is  $\mathbf{0}$ .

**Proof.** The characteristic P-vector of the support of a P-invariant  $I$  is exactly  $I$  itself. By definitions of P-invariants and characteristic T-vectors, this theorem apparently holds.  $\square$

**Theorem 2.** Let  $S$  be a siphon of net  $N=(P, T, F)$  and  $\eta_S$  be its characteristic T-vector. We can conclude that  $\{t \in T \mid \eta_S(t) > 0\}$ ,  $\{t \in T \mid \eta_S(t) = 0\}$ , and  $\{t \in T \mid \eta_S(t) < 0\}$  are the sets of transitions whose firings will increase, maintain, and decrease the number of tokens marked in  $S$ , respectively.

**Proof.**  $\forall t \in \{t \in T \mid \eta_S(t) > 0\}$  there exist  $D_1, D_2, D_3$  such that  $S = D_1 \cup D_2 \cup D_3$  (note that  $D_1, D_2$ , and  $D_3$  can not be empty sets simultaneously), and  $\forall p \in D_1, p \in t$ ;  $\forall p \in D_2, p \in \cdot t$ ;  $\forall p \in D_3, p \notin t \cup \cdot t$ . According to the firing rules of Petri nets, the firing of  $t$  will increase the number of tokens in  $D_1$ , decrease that of tokens in  $D_2$ , but maintain that in  $D_3$ . By Definition 2, if  $t \in \{t \in T \mid \eta_S(t) > 0\}$  then one will have  $|D_1| > |D_2|$ . Therefore,  $\forall t \in \{t \in T \mid \eta_S(t) > 0\}$ , the token increments in  $S$  will be  $|D_1| - |D_2| (\eta_S(t))$  by the firing of  $t$ . The two other cases can be similarly proved.  $\square$

**Definition 3.** Let  $S_0, S_1, S_2, \dots$ , and  $S_n (n \in \mathbb{N}/\{0, 1\})$  be SMS of a net  $N$  and  $\eta_{S_i}$  be the characteristic T-vector of  $S_i, i=0, 1, 2, \dots, n$ .  $S_0$  is called a redundant SMS (denoted by  $RS$ ) with respect to  $S_1, S_2, \dots$ , and  $S_n$  if  $\eta_{S_0} = \eta_{S_1} + \eta_{S_2} + \dots + \eta_{S_n}$  holds. We denote the set of redundant SMS in a net by  $\Pi_{RS}$ .

**Definition 4.** Let  $\Pi$  be the set of SMS of  $N$ .  $\forall S \in \Pi$ , if  $\neg \exists S_1, S_2, \dots$ , and  $S_n \in \Pi \setminus S$  such that  $\eta_{S_1} + \eta_{S_2} + \dots + \eta_{S_n} = \eta_S$  holds,  $S$  is called an elementary siphon. Obviously, we can get  $\Pi_{ES} \cup \Pi_{RS} = \Pi$ .

## 3 Solution to the elementary siphons in $S^3PR$

The computation for SMS is a necessity for the approach in [4]. It is well known that theoretically, the time complexity of traditional algorithms of siphon computation for general Petri nets is exponential with respect to the size of a Petri net although it is not the case practically. We develop a method to obtain SMS in an  $S^3PR$  net based on its structural analysis. The relevant notations, definitions, and results about  $S^3PR$  can be referred to [4].

**Definition 5.** Let  $\{r_1, r_2, \dots, r_m\} \subseteq P_R (m \in \mathbb{N}/\{0, 1\})$  be a set of resources in an  $S^3PR (N, M_0)$ .  $\{r_1, r_2, \dots, r_m\}$  is called a resource circuit, denoted by  $L$ , if  $\cdot r_1 \cap r_2 \neq \emptyset, \cdot r_2 \cap r_3 \neq \emptyset, \dots$ , and  $\cdot r_m \cap r_1 \neq \emptyset$  hold. Note that the number of expressions may be larger than  $m$  due to the fact that a resource can be shared by two or more processes.

**Theorem 3.** Let  $L = \{r_1, r_2, \dots, r_m\}$  be a resource circuit of an  $S^3PR N, N=(P \cup P^0 \cup P_R, T, F)$ .  $S = \{r_1, r_2, \dots, r_m\} \cup \{p \mid p \in \bigcup_{r \in L} H(r) \wedge (p \cdot \cap P) \not\subseteq \bigcup_{r \in L} H(r)\}$  is a minimal



siphon in  $N$ . And if  $S$  does not contain the support of any P-invariant, then  $S$  is an SMS.

**Proof.** We first claim that  $S$  is a siphon. For this, we have to prove  $\forall t \in \cdot S, t \in S^{\cdot}$ .  $\forall t \in \cdot S$ , either  $t \in \cdot \{r_1, r_2, \dots, r_m\}$  or  $t \in \cdot \{p \mid p \in \bigcup_{r \in L} H(r) \wedge (p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)\}$  holds. We accordingly have the following two cases.

1)  $t \in \cdot \{r_1, r_2, \dots, r_m\}$  means  $\exists i \in \{1, 2, \dots, m\}, t \in \cdot r_i$ . By the definition of a resource circuit, two subcases are considered.

a) There exists  $j \in \{1, 2, \dots, m\}$  such that  $\cdot r_i \cap r_j \neq \emptyset$ . If  $t \in \cdot r_i \cap r_j, t \in \cdot \{r_1, r_2, \dots, r_m\}^{\cdot}$  holds. b) There does not exist  $j \in \{1, 2, \dots, m\}$  such that  $t \in \cdot r_i \cap r_j$ . From the definitions of  $S^3PR^{[4]}$ , there must exist a state place  $p \in H(r_i)$  such that  $t \in \cdot p$  holds. Therefore, one needs to prove  $p \in S$ . Since  $S = \{r_1, r_2, \dots, r_m\} \cup \{p \mid p \in \bigcup_{r \in L} H(r) \wedge (p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)\}$ , one equivalently has to prove  $(p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)$ . By contradiction, assume  $(p^{\cdot} \cap P) \subseteq \bigcup_{r \in L} H(r)$ . Hence we have  $\exists j \in \{1, 2, \dots, m\}, (p^{\cdot} \cap P) \subseteq H(r_j)$  and  $t \in \cdot r_i \cap r_j$  by definitions of  $S^3PR$ . This is clearly contradictory to the condition that there does not exist  $j \in \{1, 2, \dots, m\}$  such that  $t \in \cdot r_i \cap r_j$ . Consequently, if there exists a transition  $t \in \cdot \{r_1, r_2, \dots, r_m\}$  and does not exist  $j \in \{1, 2, \dots, m\}$  such that  $t \in \cdot r_i \cap r_j$ , there certainly exists a place  $p \in H(r_i)$  such that  $t \in \cdot p$  and  $p \in S$ , i. e.,  $t \in S^{\cdot}$ . Therefore,  $\forall t \in \cdot \{r_1, r_2, \dots, r_m\}, t \in S^{\cdot}$  holds.

2)  $t \in \cdot \{p \mid p \in \bigcup_{r \in L} H(r) \wedge (p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)\}$  means  $\exists r_i \in L (i \in \{1, 2, \dots, k\}), p \in H(r_i)$  such that  $t \in \cdot p$ . By definitions of  $S^3PR$ ,  $t \in \cdot r_i$  holds. Thus we can conclude that  $\forall t \in \cdot \{p \mid p \in \bigcup_{r \in L} H(r) \wedge (p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)\}$  means  $t \in S^{\cdot}$ .

By the proofs for cases 1) and 2), one can get  $\forall t \in \cdot (\{r_1, r_2, \dots, r_m\} \cup \{p \mid p \in \bigcup_{r \in L} H(r) \wedge (p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)\}), t \in S^{\cdot}$  holds, i. e.,  $\cdot S \subseteq S^{\cdot}$ . Trivially,  $S$  is a siphon.

Next we prove  $S$  is a minimal siphon. By contradiction. Assume that  $S$  is not a minimal siphon. That is to say, there exists a siphon  $S_X$  such that  $S_X \subset S$  holds. Let  $S = S_R \cup S_P, S_R = S \cap P_R, S_P = S \setminus S_R, S_X = S_{XR} \cup S_{XP}, S_{XR} = S_X \cap P_R$ , and  $S_{XP} = S \setminus S_{XR}$ . If  $S_X \subset S$  is true, then one of the following three cases holds: a)  $S_{XR} = S_R, S_{XP} \subset S_P$ ; b)  $S_{XR} \subset S_R, S_{XP} = S_P$ ; and c)  $S_{XR} \subset S_R, S_{XP} \subset S_P$ . We first deal with case a). By  $S_{XP} \subset S_P$ , there exists at least a place  $p \in H(r)$  such that  $r \in S_R (S_{XR}), p \in S_P$  and  $p \notin S_{XP}$  are true. From the definitions of  $S^3PR$ , we know that there exists a transition  $t \in \cdot p \cap \cdot r_i$  such that  $t \in \cdot S_{XR}$  and  $t \in \cdot S_X$ , as shown in Fig. 1. Owing to  $p \notin S_{XP}$ , there does not exist a place  $p_X \in S_{XP}$  such that  $\exists t \in \cdot p \cap \cdot p_X$  and hence  $t \in S_{XP}^{\cdot}$  holds. We can see that  $t \notin S_{XP}^{\cdot}$ . Moreover, there impossibly exists a place  $r_j \in S_{XR} (S_R)$  such that  $t \in \cdot r_j$ . Otherwise, it leads to  $(p^{\cdot} \cap P) \subseteq \bigcup_{r \in L} H(r)$  which is contradictory to  $(p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)$  defined in  $S$ . Hence  $t \notin S_{XR}^{\cdot}$  holds. As a result, we can conclude that  $S_X$  is not a siphon since there exists a transition  $t$  such that both  $t \in \cdot S_X$  and  $t \notin S_{XR}^{\cdot} \cup S_{XP}^{\cdot} (t \notin S_X^{\cdot})$  hold, which is clearly contradictory to the assumption. Therefore,  $S$  is a minimal siphon. Case b) and c) can be similarly proved.




Fig. 1 The case of  $S_{XR} = S_R, S_{XP} \subset S_P$

Consequently,  $S = \{r_1, r_2, \dots, r_m\} \cup \{p \mid p \in \bigcup_{r \in L} H(r) \wedge (p^{\cdot} \cap P) \not\subseteq \bigcup_{r \in L} H(r)\}$  is a minimal siphon in  $S^3PR$ . And if  $S$  does not contain the support of any P-invariant,  $S$  is an SMS accordingly.  $\square$

**Definition 6.** Let  $L_1$  and  $L_2$  be two resource circuits. We say that  $L_1$  and  $L_2$  are connected if  $\exists r \in P_R, r \in L_1 \cap L_2$ .

**Definition 7.** Let  $L_1, L_2, \dots$ , and  $L_n (n \in \mathbb{N} / \{0, 1\})$  be resource circuits. We call  $L_1 \cup L_2 \cup \dots \cup L_n$  a resource chain if  $\forall i \in \{1, 2, \dots, n\}, \exists j \in \{1, 2, \dots, n\} \setminus \{i\}$  such that  $L_i$  and  $L_j$



are connected.

Let  $LC$  denote a resource chain. Note that a set of resources may be both a resource circuit and a resource chain. In that case, we preferentially treat it as a resource circuit.

**Theorem 4.** Let  $LC = \{r_1, r_2, \dots, r_m\}$  be a resource chain of an  $S^3PR$ .  $S = \{r_1, r_2, \dots, r_m\} \cup \{p \mid p \in \bigcup_{r \in LC} H(r) \wedge (p \cdot \cap P) \not\subseteq \bigcup_{r \in LC} H(r)\}$  is a siphon. If  $S$  neither contains the support of any P-invariant nor is a superset of any siphon, then  $S$  is an SMS.

**Proof.** Similar to the proof of Theorem 3.

**Theorem 5.** Let  $S = S_R \cup S_P$  be a siphon of an  $S^3PR$ , where  $S_P = \{p \mid p \in (\bigcup_{r \in L} H(r)) \wedge (p \cdot \cap P) \not\subseteq (\bigcup_{r \in L} H(r))\}$  and  $S_R = \{r_1, r_2, \dots, r_m\}$ . We can conclude  $S_R$  is an  $L$  or an  $LC$ .

**Proof.** By induction.

First we claim the case of  $|S_R| = 2$ , i. e.,  $S_R = \{r_i, r_j\}$  (It is proved in [4] that  $|S_R| > 1$ , where  $S$  is a siphon in an  $S^3PR$ ). From definitions for SMS in  $S^3PR$ , there exists a place  $p \in H(r_i)$  such that  $p \notin S_P$ . If  $\{t\} = p \cdot \cap r_i$  we have  $\exists r \in P_R, \{t\} = r \cdot \cap r_i$ . Hence one can get  $r = r_j$ . Otherwise, we have  $t \notin S$  and  $S$  is not a siphon. As a result  $\{t\} = r_j \cdot \cap r_i$ , i. e.,  $r_j \cdot \cap r_i \neq \emptyset$  holds. Similarly, we can prove that  $r_j \cdot \cap r_i \neq \emptyset$  holds as well. Therefore  $\{r_i, r_j\}$  is a resource circuit. The case  $|S_R| = 2$  is proved.

Assume that when  $|S_R| = m$ ,  $\{r_1, r_2, \dots, r_m\}$  is a resource circuit or chain. The case  $|S_R| = m + 1$  is proved as follows. If  $r_m \cdot \cap r_{m+1} = \emptyset$  holds, we have  $p \in S, \forall p \in H(r_{m+1})$ . Otherwise, there exists a place  $p \rightarrow \in S, \{t\} = p \cdot \cap r_{m+1} \wedge t \notin S$ . This means  $\{r_{m+1}\} \cup H(r_{m+1})$  is included in  $S$ . While  $\{r_{m+1}\} \cup H(r_{m+1})$  is the support of a P-invariant, we can see that  $S$  is thus not a strict siphon. Consequently,  $r_m \cdot \cap r_{m+1} = \emptyset$  is not possible. Assume that  $\{t\} = r_m \cdot \cap r_{m+1}$ . We have  $\{t\} = p' \cdot \cap r_m$ , where  $p' \in H(r_m)$ . Obviously,  $p' \notin S$  holds. Furthermore, assume  $\{t\} = p \cdot \cap r_{m+1}$ , where  $p \in H(r_{m+1})$ . One can get  $p \in S$ . Moreover, there exists a directed path between  $p_1$  and  $p_2$ , and  $p_1 \notin S$ , where  $p_1 \in H(r_{m+1})$  and  $p_2 \in H(r_m)$ . Otherwise,  $S$  will contain  $\{r_{m+1}\} \cup H(r_{m+1})$ . Let  $\{t'\} = p_1 \cdot \cap r_{m+1}$ . Due to  $p_1 \notin S, t' \in r_m$  holds. Otherwise,  $t \in r_{m+1}$ . By  $t \in S$ , we have  $r_{m+1} \cdot \cap r_m = \{t'\} \neq \emptyset$ . One can see that  $\{r_1, r_2, \dots, r_m\}$  and  $\{r_{m+1}\}$  are connected.  $\{r_1, r_2, \dots, r_m, r_{m+1}\}$  is either an  $L$  or an  $LC$ .  $\square$

The sufficient and necessary conditions under which a set of places of an  $S^3PR$  net is an SMS are given by Theorems 3, 4, and 5. Accordingly, we can use Theorems 3 and 4 to calculate SMS. The outline of our algorithm is: 1) Find all  $L$ s of the net; 2) Find all  $LC$ s of the net; 3) Calculate all strict siphons and siphons of the net based on  $L$ s and  $LC$ s, respectively; and 4) Eliminate each strict siphon which contains the support of any P-invariant and each non-minimal siphon which is a superset of any siphon.

For example, Fig. 2 is the Petri net model of an FMS and it belongs to  $S^3PR$  class. There are three resource circuits, namely  $L_1 = \{M1, R1\}$ ,  $L_2 = \{M2, R1\}$ , and  $L_3 = \{M3, R1, M4, R2\}$  and four resource chains, namely  $LC_1 = \{M1, R1, M2\}$ ,  $LC_2 = \{M1, M3, R1, M4, R2\}$ ,  $LC_3 = \{M2, M3, R1, M4, R2\}$ , and  $LC_4 = \{M1, M2, M3, R1, M4, R2\}$ . From these resource circuits and chains, one can get seven siphons,  $Q_1 = \{p_2, p_5, p_{11}, p_{13}, M1, R1\}$ ,  $Q_2 = \{p_2, p_5, p_{13}, M2, R1\}$ ,  $Q_3 = \{p_2, p_7, p_{11}, p_{13}, M3, R1, M4, R2\}$ ,  $Q_4 = \{p_5, p_{13}, M1, R1, M2\}$ ,  $Q_5 = \{p_2, p_7, p_{11}, p_{13}, M1, M3, R1, M4, R2\}$ ,  $Q_6 = \{p_2, p_7, p_{13}, M2, M3, R1, M4, R2\}$ , and  $Q_7 = \{p_7, p_{13}, M1, M2, R1, M3, R2, M4\}$ . It can be verified that five of them are SMS, namely  $S_1 = \{p_2, p_5, p_{13}, M2, R1\}$ ,  $S_2 = \{p_2, p_7, p_{11}, p_{13}, M3, R1, M4, R2\}$ ,  $S_3 = \{p_5, p_{13}, M1, R1, M2\}$ ,  $S_4 = \{p_2, p_7, p_{13}, M2, M3, R1, M4, R2\}$ ,  $S_5 = \{p_7, p_{13}, M1, M2, R1, M3, R2, M4\}$ .

In the following a method to compute elementary siphons is proposed.

**Definition 8.** Let  $N = (P, T, F)$  be a net with  $|P| = m$ ,  $|T| = n$  and we assume  $N$  has  $k$  SMS,  $S_1, S_2, \dots$ , and  $S_k$ ,  $m, n, k \in IN$ . Let  $\lambda_{S_i}(\eta_{S_i})$  be the characteristic P(T)-



vector of SMS  $S_i$ . We define  $[\lambda]_{k \times m} = [\lambda_{S_1}^T | \lambda_{S_2}^T | \dots | \lambda_{S_k}^T]^T$  and  $[\eta]_{k \times n} = [\lambda]_{k \times m} \times C_{m \times n} = [\eta_{S_1}^T | \eta_{S_2}^T | \dots | \eta_{S_k}^T]^T$ .  $[\lambda]$  ( $[\eta]$ ) is called the characteristic P(T)-vector matrix of the SMS of  $N$ .




Fig. 2 The Petri net model of an FMS




Fig. 3 The live Petri net with 3 additional places

**Theorem 6.** Let  $N$  be a net and  $[\eta]$  be the characteristic T-vector matrix of the SMS of it. The number of elementary siphons in  $N$  is equal to the rank of  $[\eta]$ .

**Proof.** Assume  $N$  has  $k$  SMS and  $k'$  elementary siphons ( $k \geq k'$ ). Obviously, there are  $k - k'$  redundant SMS in  $N$ . By Definition 3,  $\eta_{S_i}$  ( $i = k' + 1, k' + 2, \dots, k$ ) can be linearly represented by  $\eta_{S_j}$  ( $j = 1, 2, \dots, k'$ ). According to the definition of the rank of a matrix, we have the rank of  $[\eta]_{k \times n}$  is  $k'$ .  $\square$

In Fig. 2, it is easy to verify that  $\eta_4 = \eta_1 + \eta_2$  and  $\eta_5 = \eta_2 + \eta_3$ . Hence, the rank of  $[\eta]$  is 3. Thus  $S_1, S_2$  and  $S_3$  are elementary siphons and  $S_4$  and  $S_5$  are redundant siphons.

#### 4 Deadlock prevention policy

In [4], to keep all SMS being marked at any reachable marking, a place and several arcs are added to the original net system for each SMS, which leads to a more complex Petri net controller. However, only a small number of SMS are considered in our method. All SMS of a net system can possibly be marked if its elementary siphons are controlled. For the case that there exists an emptiable siphon when all elementary siphons are controlled, we have to add a place to control it using the control approach developed in [4]. Note that in [4] it is guaranteed that no new siphon is generated owing to the addition of control places. This research investigates conditions under which an SMS in a Petri net system can always be marked by controlling its elementary siphons.

As stated in Definition 3, we use  $RS$  to denote a redundant siphon,  $RS_R = RS \cap P_R$  to denote the set of resources of  $RS$ , and  $C_{RS} = (\cup \{H(r), r \in RS_R\}) \setminus RS$  to denote the complementary set of  $RS$ . Elementary siphons can be similarly described.

**Definition 9.** Let  $(N, M_0)$  be a Petri net system and  $RS$  be a redundant siphon of  $N$ . We say  $RS$  is a controllable redundant siphon by elementary siphons if elementary siphons of  $N$  are controlled means that  $RS$  is controlled.

Let  $(N, M_0)$  be an  $S^3PR$ . Assume that there are  $m$  elementary siphons  $S_1, S_2, \dots$ , and  $S_m$  in the net system. By the prevention deadlock method in [4], we add  $m$  control places  $V_{S_1}, V_{S_2}, \dots$ , and  $V_{S_m}$  to control  $S_1, S_2, \dots$ , and  $S_m$ , respectively. The new net system is denoted as  $(N_A, M_{0A})$ . By the siphon control method in [4], three control places  $V_{S_1}, V_{S_2}$ , and  $V_{S_3}$  are added to the net model in Fig. 2. The resultant Petri net which is live is shown



in Fig. 3. This can be verified by the following procedures. Next we discuss the conditions under which a redundant siphon  $RS$  of  $(N, M_0)$  can not be emptied in  $(N_A, M_{0A})$ .

An empty redundant siphon  $RS$  at any marking  $M_A \in R(N_A, M_{0A})$  must satisfies conditions Cond-1, Cond-2, and Cond-3 as follows. That means if one of these conditions does not hold for  $RS$ , it will always be marked at  $M_{0A}$ . For a siphon  $S$ ,  $P_S$  and  $C_S$  are defined in [4].

Cond-1. By the definition of  $C_{RS}$ ,  $C_{RS} \cup RS$  is the support of a P-invariant, which is the union of  $RS_R$  and  $(\cup \{H(r), r \in RS_R\})$ . Note that  $RS_R = RS \cap P_R$  is the set of resources of  $RS$  and  $\cup \{H(r), r \in RS_R\}$  is the union of holders of those resources. If  $RS$  is unmarked at marking  $M_A$ , we have  $\sum M_A(p | p \in C_{RS}) = \sum M_{0A}(p | p \in RS) = \sum M_{0A}(p | p \in RS_R)$  due to  $\forall p \in RS_P, M_{0A}(p) = 0$ . Note that the union of the set consisting of a resource of  $RS$  and the holders of the resource is the support of a P-invariant. According to the properties of P-invariants,  $\forall r \in RS_R, M_A(r) + \sum M_A(p | p \in H(r)) = M_A(r) + \sum M_A(p | p \in C_{RS} \cap H(r)) + \sum M_A(p | p \in RS \cap H(r)) = M_{0A}(r)$  trivially holds, i. e.,  $\forall r \in RS_R, \sum M_A(p | p \in C_{RS} \cap H(r)) = M_{0A}(r)$ . This equality means that when  $RS$  is unmarked, all tokens in each resource of  $RS$  are "stolen" by the holders of the resource, which are included in  $RS$ .

Cond-2. Suppose that  $m$  control places are added for  $m$  elementary siphons in  $N$ . From the definition of  $P_S$ ,  $C_S \subseteq P_S$  clearly holds. Due to the properties of P-invariants, we can have the following relationship when an  $RS$  is unmarked:  $\forall j \in \{1, 2, \dots, m\}, \sum M_{0A}(p | p \in S_j) - 1 = M_{0A}(V_{S_j}) = M_A(V_{S_j}) + \sum M_A(p | p \in P_{S_j}) \geq M_A(V_{S_j}) + \sum M_A(p | p \in (C_{RS} \cap P_{S_j})) \geq \sum M_A(p | p \in (C_{RS} \cap P_{S_j}))$ , i. e.,  $\forall j \in \{1, 2, \dots, m\}, \sum M_{0A}(p | p \in S_j) - 1 \geq \sum M_A(p | p \in (C_{RS} \cap P_{S_j}))$ .

Cond-3. Assume that an  $S^3$  PR is composed by  $k$   $S^2$  P ( $N_i = (P_i \cup \{p_i^0\}, T_i, F_i)$ ) via shared resources. There are thus  $k$  P-invariants due to  $k$   $S^2$  P, whose supports are  $\|I_i\| = P_i \cup \{p_i^0\}$ ,  $i \in \{1, 2, \dots, k\}$ . Whether  $\|I_i\| \cap C_{RS} \neq \emptyset$ , we always have, by the definition of P-invariants, the following relationship:  $\forall i \in \{1, 2, \dots, k\}, \sum M_A(p | p \in C_{RS} \cap \|I_i\|) \leq \sum M_{0A}(p | p \in \|I_i\|) = M_{0A}(p \in \{p_i^0\})$ .

For an  $RS$ , by solving the set of inequalities derived from Cond-1, Cond-2, and Cond-3, we can find the conditions under which it is emptied. Otherwsie,  $RS$  can always be marked if there does not exist a feasible solution. In other words,  $RS$  is controlled by its elementary siphons.

Note that if, for an  $S^2$  PR, the initial number of tokens in  $M_{0A}(p_i^0)$  is larger than or equal to the sum of tokens initially marked at the resources possessed by the  $S^2$  PR, the inequalities derived from Cond-3 must hold. Therefore, nothing but the inequalities derived from Cond-1 and Cond-2 need to be solved. When a redundant siphon is not controllable by the above methods, an additional control place is added by the method proposed in [4]. If all siphons in the target net system are controlled, the augmented net system is live by the results of [4].

Let us examine if the redundant siphons in Fig. 2 are controllable after all elementary siphons are controlled. First we deal with  $S_4 = \{p_2, p_7, p_{13}, M2, M3, R1, M4, R2\}$ . For a redundant siphon  $RS$ , we have  $C_{RS} = (\cup \{(H(r), r \in RS_R)\}) \setminus RS$ . Thus  $C_{RS_4} = (H(M2) \cup H(M3) \cup H(R1) \cup H(M4) \cup H(R2)) \setminus RS_4 = \{p_3, p_{12}, p_6, p_2, p_5, p_{11}, p_{13}, p_{10}, p_7, p_9\} \setminus RS_4 = \{p_3, p_{12}, p_6, p_5, p_{11}, p_{10}, p_9\}$ .  $C_{RS_4} \cap H(M2) = \{p_3, p_{12}\}$ ,  $C_{RS_4} \cap H(M3) = \{p_6\}$ ,  $C_{RS_4} \cap H(R1) = \{p_5, p_{11}\}$ ,  $C_{RS_4} \cap H(M4) = \{p_{10}\}$ ,  $C_{RS_4} \cap H(R2) = \{p_9\}$ .



We can obtain the following relationships (1) ~ (5), (6) ~ (8), and (9), (10) by Cond\_1, Cond\_2, and Cond\_3, respectively.

$$\sum M_A(p \mid p \in C_{RS4} \cap H(M2)) = M_{0A}(M2) = 1 \Rightarrow M_A(p_3) + M_A(p_{12}) = 1 \quad (1)$$

$$\sum M_A(p \mid p \in C_{RS4} \cap H(M3)) = M_{0A}(M3) = 1 \Rightarrow M_A(p_6) = 1 \quad (2)$$

$$\sum M_A(p \mid p \in C_{RS4} \cap H(R1)) = M_{0A}(R1) = 1 \Rightarrow M_A(p_5) + M_A(p_{11}) = 1 \quad (3)$$

$$\sum M_A(p \mid p \in C_{RS4} \cap H(M4)) = M_{0A}(M4) = 1 \Rightarrow M_A(p_{10}) = 1 \quad (4)$$

$$\sum M_A(p \mid p \in C_{RS4} \cap H(R2)) = M_{0A}(R2) = 1 \Rightarrow M_A(p_9) = 1 \quad (5)$$

$$M_A(p_3) + M_A(p_9) + M_A(p_{10}) + M_A(p_{11}) + M_A(p_{12}) \leq 1 \text{ (for } S_1) \quad (6)$$

$$M_A(p_3) + M_A(p_5) + M_A(p_6) + M_A(p_9) + M_A(p_{10}) \leq 3 \text{ (for } S_2) \quad (7)$$

$$M_A(p_3) + M_A(p_9) + M_A(p_{10}) + M_A(p_{11}) + M_A(p_{12}) \leq 2 \text{ (for } S_3) \quad (8)$$

$$M_A(p_3) + M_A(p_5) + M_A(p_6) \leq 6 \quad (9)$$

$$M_A(p_9) + M_A(p_{10}) + M_A(p_{11}) + M_A(p_{12}) \leq 6 \quad (10)$$

The complementary sets of elementary siphons are  $C_{S1} = \{p_3, p_{11}, p_{12}\}$ ,  $C_{S2} = \{p_5, p_6, p_9, p_{10}\}$ , and  $C_{S3} = \{p_2, p_3, p_4, p_{11}, p_{12}\}$ . Due to the definitions of  $P_S$  and  $C_S$ , where  $S$  is a siphon, we have  $P_{S1} = \{p_2, p_3, p_9, p_{10}, p_{11}, p_{12}\}$ ,  $P_{S2} = \{p_2, p_3, p_4, p_5, p_6, p_9, p_{10}\}$ ,  $P_{S3} = \{p_2, p_3, p_4, p_9, p_{10}, p_{11}, p_{12}\}$ .  $C_{RS4} \cap P_{S1} = \{p_3, p_9, p_{10}, p_{11}, p_{12}\}$ ,  $C_{RS4} \cap P_{S2} = \{p_3, p_5, p_6, p_9, p_{10}\}$ , and  $C_{RS4} \cap P_{S3} = \{p_3, p_9, p_{10}, p_{11}, p_{12}\}$ . The supports of the P-invariants derived from  $S^2P$  in Fig. 2 are  $\|I_1\| = \{p_1^0, p_2, p_3, p_4, p_5, p_6, p_7\}$  and  $\|I_2\| = \{p_2^0, p_9, p_{10}, p_{11}, p_{12}, p_{13}\}$ . Thus we have  $C_{RS4} \cap \|I_1\| = \{p_3, p_5, p_6\}$ ,  $C_{RS4} \cap \|I_2\| = \{p_9, p_{10}, p_{11}, p_{12}\}$ . Obviously, (6) does not hold when (4) and (5) are taken into account. Thus  $RS_4$  is controlled in Fig. 3. We can also verify that another redundant siphon of Fig. 2 is controlled, as well. Therefore, no more control place needs to be added and the Petri net shown in Fig. 3 is live. To make the Petri net in Fig. 2 live, three control places and 14 arcs are added when our method is employed. However, five control places and 22 arcs are added when the method in [4] is used for this example. The number of reachable markings generated is 88 by either method. Our case study reveals that the more complex a net, the better performance of our method. For the net in Fig. 8 of [4], our method uses 6 control places and 32 arcs to make the net system live while 18 control places and 106 arcs were added to the original net model to achieve the same purpose.

## 5 Discussions and conclusions

In this paper, we propose a new deadlock prevention policy. By preventing a smaller number of SMS from being emptied, deadlocks can be prevented for ordinary Petri nets and liveness can be guaranteed for  $S^3PR$ , a special class of Petri nets proposed in [4]. The advantage of this method lies in the fact that the final Petri net model is of much less additional places and arcs. In addition, we propose a method to compute elementary siphons and SMS in an  $S^3PR$  system with less computation burden. The concept of elementary siphons looks promising in deadlock prevention problems arising in FMS context. Further research will apply this method to more general Petri net classes.

## References

- 1 Ezpeleta J, Martinez J. Synthesis of live models for a class of FMSs. In: Proceedings of the IEEE International Conference on Robotics and Automation, Atlanta; IEEE Press, 1993
- 2 Zhou M C, Dicesare F. Parallel and sequential mutual exclusion for Petri net modeling of manufacturing systems with shared resources. *IEEE Transactions on Robotics and Automation*, 1991, 7(4): 515~527
- 3 Bananszak K, Krogh B H. Deadlock avoidance in flexible manufacturing systems with concurrently competing process flows. *IEEE Transactions on Robotics and Automation*, 1990, 6(6): 724~734
- 4 Ezpeleta J, Martinez J. A Petri net based deadlock prevention policy for flexible manufacturing systems. *IEEE*

- Transactions on Robotics and Automation*, 1995, **11**(2): 173~184
- 5 Iordache M V, Moody J O, Antasklis P J. A method for deadlock prevention in discrete event systems using Petri nets. Technical Report of the ISIS Group ISIS-98-004, USA; University of Notre Dame, 1998
  - 6 Zhou M C, Dicesare F. Petri Net Synthesis for Discrete Event Control of Manufacturing Systems. New Jersey: Kluwer Academic Publishers, 1993
  - 7 Visvanadham N, Narahary Y, Johnson T L. Deadlock prevention and deadlock avoidance in flexible manufacturing systems using Petri net models. *IEEE Transactions on Robotics and Automation*, 1990, **6**(6): 713~723
  - 8 Wysk R A, Yang N S, Joshi S. Detection of deadlocks in flexible manufacturing systems. *IEEE Transactions on Robotics and Automation*, 1991, **7**(6): 853~859
  - 9 Li Z W, Jia J Y, Ye S H. A formal design method of Petri net controllers for sequential manufacturing systems. *Acta Automatica Sinica*, 1997, **9**(4): 213~219(in Chinese)
  - 10 Murata T. Petri nets: Property, analysis, and applications. *IEEE Proceedings*, 1989, **77**(4): 41~80

**LI Zhi-Wu** Professor, received his Ph. D. degree in 1995 from Xidian University. He has been with the School of Electro-Mechanical Engineering, Xidian University since 1995. As a visiting scholar, he is with the Systems Control Group, Department of Electrical & Computer Engineering, University of Toronto from 2002 to 2003. His research interests include production automation and supervisory control of discrete event systems.

**Wang An-Rong** Master student in Xidian University. His research interests include supervisory control of discrete event systems.

## 基于 Petri 网的柔性制造系统一种预防死锁方法

李志武 王安荣

(西安电子科技大学机电工程学院 西安 710071)

(E-mail: zhwli@xidian.edu.cn; an-rong-wang@sina.com)

**摘要** 基于 Petri 网的结构特性分析,研究了 FMS(柔性制造系统)一种预防死锁方法.提出了 Petri 网的一种特殊拓扑结构——基本信标的概念.在 Petri 网中基本信标的集合是 SMS(严格极小信标)集合的一个真子集.尤其在大型 Petri 网系统中,基本信标的集合比 SMS 的集合要小得多.对于 Petri 网的一个子类  $S^3PR$ ,只对每一个基本信标添加一个库所使其不被清空,就可实现预防死锁,也就是说无须控制  $S^3PR$  的所有 SMS 而达到无信标被清空的目的.此外,对于  $S^3PR$ ,还提出了一种求取 SMS 和基本信标的方法.相对于现在普遍采用的控制所有 SMS 来预防死锁的策略,其具三方面优势.1)只需控制少量的 SMS 即所谓的基本信标.相应地,添加少量的控制库所和连接弧,就可得到无死锁或活的 Petri 网.2)不需要先行计算出极小信标的集合.3)明显地,这种方法更适合大型 Petri 网系统.我们通过穿插在文中的例子来说明这些方法.

**关键词** Petri 网, 预防死锁, 基本信标, 柔性制造系统

**中图分类号** TP278